



1. A VALVE BOX TOP SECTION SHALL BE USED AS A CURB BOX COVER WHENEVER THE CURB BOX FALLS INTO NEW OR REPLACED CONCRETE SIDEWALK, DRIVE APPROACH, OR BITUMINOUS PAVEMENT AREAS.
- ② VALVE BOX TOP SECTION SHALL BE OF THE SCREW TYPE, HAVE A MINIMUM INSIDE SHAFT DIAMETER OF 5 1/4", AND HAVE A CAP WITH THE WORD "WATER" PLAINLY MARKED ON TOP.
3. IN ALL RESPECTS THE VALVE BOX SHALL BE EQUAL TO TYLER/UNION-10T-UPC#144939.
4. VALVE BOX COVER SHALL BE OF THE LOCKING TYPE, EQUAL TO A TYLER/UNION UPC#145462.
- ⑤ CURB BOX RISER CAP IS TO BE A MINIMUM OF 4" AND A MAXIMUM OF 6" BELOW THE FINISHED PAVEMENT GRADE.
6. CURB BOX RISER ADJUSTMENT, AND THE FURNISHING & INSTALLATION OF VALVE BOX TOP SECTION AND COVER, SHALL BE INCLUDED IN PAYMENT FOR CURB BOX COVER.

DEPARTMENT OF PUBLIC WORKS CITY OF ROCHESTER, MINNESOTA			
CURB BOX COVER			
<i>Douglas Nelson</i> ASST. CITY ENGINEER		<i>Paul W. Finner</i> DIRECTOR	
SHT 1 OF 1 SHTS	DATE REVISED 6/15/07	PLATE NO. 1-10	REV. B